



KARNATAKA FIRE AND EMERGENCY SERVICES DEPARTMENT

Office of the District Fire Officer,
Banawadi Fire Station, Bengaluru-560 043.
080-22971540/22971611.



No. 22/SCHOOL/FSCR/DFO/BWFS/2024.

Date: 22-04-2024

ANNEXURE - B

Group- B Educational Building.

To,

**The Secretary,
ITI Education Committee / ITI Central School,
Vidya Mandir,
Dooravaninagar,
Bengaluru-560 016.**

Sub: Issue of '**Fire Safety Compliance Report**' with respect to fire prevention, fire fighting and evacuation measures maintained required at **ITI Education Committee / ITI Central School, Vidya Mandir, Dooravaninagar, Bengaluru-560 016.**

Ref: 1. Fire safety recommendation No.22/SCHOOL/FSR/DFO/BWFS/2024, Dated: 17-04-2024.
2. Your request letter dated: 20-04-2024.
3. DFO Banawadi inspection report, Dated: 22-04-2024.

* * * * *

With reference to subject above cited, 'fire safety recommendation' was issued with reference (1) to the premises of **ITI Education Committee / ITI Central School, Vidya Mandir, situated at Dooravaninagar, Bengaluru-560 016** with a condition to fulfill the recommendations and compliance the same within 03 months. With reference cited (2) above, the management of **ITI Education Committee / ITI Central School** had requested for the fire safety compliance report from our department. In this regard with reference cited (3) above the building was inspected by me on 22-04-2024 and submitted the report & recommended to issue fire safety compliance report.

Under the above circumstances the Karnataka Fire & Emergency Services Department is issuing the "**Fire Safety Compliance Report**" to **ITI Education Committee / ITI Central School, Vidya Mandir, situated at Dooravaninagar, Bengaluru-560 016.** Subject to proper maintenance of fire fighting systems in good working conditions and to impart training for at-least 40% of employees/staff should be trained in basic fire fighting at R.A Mundkur Fire & Emergency Academy, Bannerghatta Road, Bengaluru at an earliest.

"This fire safety compliance report is issued for the period of only one year from the date of issue and it is renewable without fail".

Yours Faithfully


22/04/2024
District Fire Officer
Karnataka State Fire and Emergency Services
Banawadi Fire Station
Banawadi, Bengaluru - 560043.

